

**ODISHA ELECTRICITY REGULATORY COMMISSION  
BIDYUT NIYAMAK BHAVAN, UNIT – VIII  
BHUBANESWAR – 751 012**

\*\*\*\*\*

**ORDER**

**No. OERC-Engg. 02/2010/(Vol-IV)/1157**

**Dated: 16.09.2015**

The Commission had issued an order on 26.11.2014 on Net Metering / Bi-directional Metering and their connectivity with respect to Rooftop Solar PV Projects which has been once amended on 18.05.2015. Now, several suggestions have been brought before the Commission for further amendment of the said order. After considering the suggestions the Commission is pleased to bring about the following amendment to the above order.

**2<sup>nd</sup> Amendments of the order dated 26.11.2014**

3<sup>rd</sup> Proviso of Para 10 of the order dated 26.11.2014 is substituted as follows:

*“Provided that for LT connections (below 11kV), the applicable meter shall comply with the existing meter standards IS 14697 for CT operated static watt-hour meters and IS-13779 for ac static watt-hour meters with additional requirement of two registers, as Import and Export register, to record the import and export of electricity.”*

This amendment order is issued with the approval of the Commission.

**Sd/-**

**SECRETARY**