## ODISHA ELECTRICITY REGULATORY COMMISSION PLOT NO.4, CHUNOKOLI, SAILASHREE VIHAR, BHUBANESWAR - 751021

\*\*\*\*\*

#### **ORDER**

No. OERC-Engg. 02/2010/(Vol-IV)/1131

## ON NET METERING/BI-DIRECTIONAL METERING & THEIR CONNECTIVITY WITH RESPECT TO SOLAR PV PROJECTS

#### 1. **Preamble:**

- (i) The Government of Odisha has been earnestly exploring different sources of clean energy to meet its increasing energy requirements, diversify sources of energy, and address potential climate change issues. The state of Odisha has fairly good potential for solar power generation with 280-300 days of sunshine in a year and Global Horizontal Irradiance of about 4.5-5.0 kWh/m²/day. Setting up of large solar power projects require huge land space whereas availability of land is a major constraint in major cities of Odisha. The prevailing scenario of declining trend in solar tariff and increasing retail tariff across consumer categories like residential, commercial and industrial consumers would encourage consumers to install solar systems. Therefore, generation from solar is set to witness appreciable scaling of capacities in Odisha in years to come.
- (ii) The Commission is mandated to promote Co-generation and Generation of electricity from Renewable Sources of Energy by providing suitable measures for connectivity with the Grid and sale of electricity to any person under Section 86 (e) of the Electricity Act, 2003. Keeping this in view, the Commission had issued order No. OERC-Engg.02/2010/ (Vol-III)/ dated 26-11-2014 and two amendments thereon on 18-05-2015 and 16-09-2015 relating to Net-metering/ Bi-directional metering for solar generation project including its LT connectivity for Government/ PSU owned and other buildings.
- (iii) In the meantime, the Commission has received several suggestions for effective implementation of the said Order, which is based on the Net Metering

Dated: 19.08.2016

- of the "prosumers". This needs revision of the order on several aspects. Therefore, the Commission orders as follows:
- (iv) The Commission recognises that distributed solar energy generation contributes to a significant reduction in transmission and distribution losses since the solar energy generated is consumed locally.
- (v) The Commission is committed to creating a regulatory framework that enables the realisation of the above mentioned targets with a significant contribution from the electricity consumer segment.
- (vi) This Order on Solar Energy Net Metering includes new provisions and revisions of earlier solar energy net metering provisions of which some of the highlights are described below:
  - (a) This Order applies to all solar power systems that are connected to the distribution system through an electrical service connection. The solar power system may be roof-mounted, ground-mounted, installed on an elevated structure or otherwise for captive use.
  - (b) In this Order the Commission has raised the cumulative solar energy capacity at distribution transformer level from the earlier 30% of transformer capacity to 75% of transformer capacity. The view of the Commission is that since the solar energy capacity for each consumer has been limited to the sanctioned or contracted load of the service connection, there is an adequate capacity capping mechanism which will ensure that the distribution transformer will not get overloaded even if all consumers who are connected to a distribution transformer install solar PV capacity of 100% of their sanctioned load. This view is reinforced after taking into account the experience of DISCOMs. It is also a fact that most of the solar energy generated by a consumer is selfconsumed or consumed in the immediate neighborhood. The Commission may however increase/decrease the level of penetration and issue renewable energy penetration limits at overall grid level if required in the future to ensure grid stability.
  - (c) There is no cap on the capacity of solar installation at a particular consumer level as long as it is within the limit of the connected load /

75% of transformer capacity. The earlier restriction of 1 MW solar capacity at a single location is removed.

(vii) The Commission hopes that with this Solar Energy Net Metering Order an enabling environment is created whereby all categories of electricity consumers including government departments, educational institutions, hospitals, industries, commercial establishments and residential consumers will be able to make a contribution to a green and sustainable Odisha and the realisation of the solar energy targets of the state.

#### 2. Definitions:

- (a) "Net-Meter" means a consumer meter which is a bi-directional energy meter for measuring the quanta of electricity flowing in opposite directions and the net quantum of electricity either consumed by the consumer or injected into the distribution system of the licensee in kWh; which shall be an integral part of the net metering system.
- (b) "Bi-directional Meter" means a consumer meter for measuring, indicating and recording quanta of electricity flowing in opposite directions (export to the licensee's distribution system and import by the consumer from distribution system) in Kwh including any other quantity as per the requirement. The net quantum of electricity either injected to the distribution system or imported by the consumer in Kwh is derived by arithmetical means. In case the meter is fixed with HT consumers the power factor will be based on the import of energy only.
- (c) Eligible consumers for Net-metering/ Bi-directional Metering: "Eligible Consumer" means a consumer of electricity in the area of supply of the distribution licensee, who uses a solar system installed in the consumer premises, to offset part or all of the consumer's own electrical energy requirements, given that such systems can be self-owned or third party owned. Both the existing and new Solar systems which comply with this order are eligible for Net-metering/ bi-directional metering.
- (d) "Settlement period for energy accounting" means the period ending 31<sup>st</sup> March of the relevant financial year.
- (e) "Prosumer" means a Consumer of electricity in the area of supply of the Distribution Licensee, who uses a self-owned or third party-owned Solar

Power System installed at the Consumer's premises, to offset part or all of the Consumer's electricity requirements.

(f) All other words and expressions used in this Order, if not specifically defined herein above, but defined in the Act, shall have the meaning assigned to them in the Act. The other words and expressions used herein but not specifically defined in this order or in the Act but defined under any other law passed by the Parliament applicable to the electricity industry in the State shall have the meaning assigned to them in such law.

#### 3. Net-metering/Bi-directional Metering based Solar PV Project:

The net metering/bi-directional metering based solar projects facilitates self-consumption of electricity generated by the project and allows for feeding the surplus energy into the network of the distribution licensee. In the context of the state of Odisha the following may be the ownership arrangements for installation of such net metering based solar systems:

- Self-owned arrangement wherein owner also owns the PV system.
- Third party ownership in which a developer owns the PV system and also enters into a lease/commercial arrangement with the owner.

#### 4. Self-owned, net metering/bi-directional based Solar PV Project:

In a self owned, net metering/ bi-directional metering based solar PV model, the owner, who is also the electricity consumer for the utility installs the solar system at his own cost. The electricity generated by the system is first used to service consumer's captive load within the owner's premises. The solar power generated in excess of the owner's electricity consumption is fed into the grid through a net-meter/ bi-directional meter. This net-generation is then credited to the owner's account and adjusted subsequently against imports from the grid in the manner specified in this order.

#### 5. Third party owned Solar PV net metering/ Bi-directional metering:

In the third party owned solar PV net metering/ bi-directional metering model, the developers or intermediaries lease out solar PV systems to interested owners. In this arrangement, the turnkey installers lease solar systems to individual owner. Alternatively, the installers can also offer an integrated service of leasing, commissioning and maintaining the systems to owners and guaranteeing standards of

performance. The electricity generated from such a system is used to meet the owner's internal electricity needs while the excess generation is fed into the grid on net metering/bi-directional metering basis.

#### 6. Capacity Limits:

The capacity of an individual solar PV system would be the available capacity of the service line connection, i.e. the sanctioned load of the consumer. The installation of net metered bi-directional metered solar systems on consumer premises will utilize the same service line and installation which is currently being used by the consumer for drawal of power from utility network for injection of excess power into the Grid. If a consumer intends to install a Solar PV System of a capacity that exceeds the Contracted Load, the consumer shall submit an application for Contracted Load enhancement along with the Solar Net Metering application. The Contracted Load enhancement application will be processed by the Distribution Licensee as per standard procedure for such applications.

### 7. **Interconnection arrangements:**

Net-metering/bi-directional metering facility shall be extended to the solar power system installed in consumer premises. These consumers are the "eligible consumers" for the purpose of net-metering/ bi-directional metering. Interconnection framework for net-metering shall address parameters including connecting voltage level, minimum technical standards for interconnection as would be indicated by the Commission from time to time under relevant regulations and orders including Orissa Electricity Regulatory Commission Distribution (Conditions of Supply) Code, 2004 and amendments thereto and as per technical standards for Connectivity of Distributed Generation resources Regulations 2013 and amendments thereto notified by Central Electricity Authority. An overview of basic grid interactive photovoltaic system is placed at Annexure-I.

#### 8. Application:

The consumer shall make an application in the prescribed format (Annexure – II) to the distribution utility along with a fee of INR 500/- (Indian Rupees Five hundred Only). The consumer can download the solar net-metering / bi-directional metering application form from the website of the distribution utility. It can also be obtained from concerned sub-division office. Before availing the permission for solar net metering / bi-direction metering of solar PV project the consumer is to enter into an

agreement with the distribution licensee in the Standard Agreement Form. Permission will be normally issued within 15 days from the date of submission of the application to the distribution utility in their Division offices provided there is feasibility for connectivity and fulfilment of other documentary requirements as per Regulations in force.

#### 9. Restrictions on level of overall or local grid penetration:

To address technical, safety and grid security issues arising out of possible reverse flow of electricity in the local grids, the distribution licensee shall provide net metering/ bi-directional metering arrangement to all eligible consumers as long as the cumulative capacity to be allowed for a particular distribution transformer shall not exceed 75% of the capacity of the distribution transformer.

The quantum of electricity consumed by an eligible consumer, who is not defined as an obligated entity from the solar system under net-metering / bi-directional metering arrangement shall qualify as deemed Renewable Purchase Obligation (RPO) for the distribution licensee/bulk supplier.

The Commission may however increase/decrease the level of penetration and issue renewable energy penetration limits at overall grid level, if required in the future to ensure grid stability.

#### **10.** Metering Arrangement:

Two meters would have to be installed by the solar power generator. One is for measuring solar generation and the other one is for Import/Export measurement. The first meter, the solar generation meter, has to be installed at the generator end after the inverter at the ground floor of the premises to facilitate easy access for meter reading. The second meter is a net meter / bi-directional meters (single phase or three phase as per requirement) capable of recording import and export of power in kWh and shall be accepted for commercial settlements. These meters should be MRI and AMR compliant. If the consumer wishes to have a record of the reading taken, he shall be allowed to do so by the licensee. The second meter have to be installed at the same location where the present meter for consumption is installed and the present meter for drawal of power from distribution utility shall be removed. The meter rent remaining unpaid at the time of installation of new meters if any shall be waived by the distribution utility.

Provided that till the BIS and CEA standards are available the following standards shall be followed. Once the standards are available, all the net meter / bi-directional meter to be installed shall follow the relevant guideline. The existing net meter / bi-directional meter already installed before the publication of standards shall be allowed to continue.

Provided that for HT connections (11kV and above), the applicable meter can be a bidirectional meter (Category-B) and complying with the existing IS-14697 and IS 15959 standards.

Provided that for LT connections (below 11kV), the applicable meter shall comply with the existing meter standards IS 14697 for CT operated static watt-hour meters and IS-13779 for ac static watthour meters with additional requirement of two registers, as Import and Export register, to record the import and export of electricity.

Provided further that all the meters should also comply with IS-15959 (Indian Standards for Data Exchange for electricity meters). There shall be a separate Solar Generation Meter to record the total solar generation in the consumer premises after the power conditioning unit.

- (a) The meters shall adhere to the standards for consumers specified by the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 and Central Electricity Authority (Installation and Operation of meters) Amendment Regulations, 2010 as amended from time to time.
- (b) The Distribution Licensee shall host the list of approved manufacturers of such meters in their website.
- (c) Installation of Check meter for the solar energy system would be optional.
- (d) The cost of meters, cost of connectivity and all other related cost for setting up the meters etc. have to be borne by the eligible consumers under guidance of the concerned distribution licensee. Either consumer or distribution licensee shall procure the meter. The distribution licensee shall test and install the same.
- (e) The meters installed shall be jointly inspected and sealed by the Licensee on behalf of both the parties. It shall be tested by the licensee and installed in the presence of the representatives of the consumer or himself and the distribution licensee with due acknowledgement. In case desired by the consumer the licensee shall allow the presence of the same during testing by intimating test date and time in advance. Position & sealing of meters will be guided by the

- same provisions as applicable to consumer meters in the Central electricity Authority's Metering Regulations/Supply Code.
- (f) The meter reading, both net meter and solar generation meter shall be taken by the distribution licensee and shall form the basis for commercial settlement. The copy of the meter reading statement shall be handed over to the consumer as soon as meter reading is taken.

#### 11. Energy Accounting:

- (a) Electricity generated from a Solar PV project shall be capped cumulatively at 90% of the electricity consumption by the eligible consumer at the end of a settlement period which ends with the financial year to allow for seasonality in generation. In case of the financial year where Commercial Operation Date (COD) occurs, the 90% capping shall be on the energy consumed by the consumer from the date of COD to the end of the financial year.
- (b) The carry forward of excess energy generation will be allowed from one billing cycle to the next billing cycle till the end of the same financial year. Any excess generation (above 90 per cent) at the end of the financial year would be considered as free energy and shall not be offset against the consumer's consumption. There shall not be any carry forward of energy to the next financial year.
- (c) The imported energy shall be eligible for normal ToD benefit as per the order of the Commission prevailing at that time.

#### 12. Billing and Payment:

- (a) The consumer shall receive a monthly net import/export bill indicating either net export to the Grid or net import from the Grid.
- (b) In case of net import bill, i.e. if any electricity is supplied by the distribution licensee to the consumer, the distribution licensee shall raise invoice for the net electricity imported after taking into account any carry forward of energy from previous billing periods in the same financial year. The net energy imported has to be billed by the Distribution Licensee as per the tariff in force applicable to that category of consumers.
- (c) In case of export of energy in excess of the consumption of the consumer in a billing cycle shall be carried forward to the next billing cycle for adjustment

- against next month's import bill if any. No interest will be payable on this carry forward energy amount.
- (d) In case of defective net metering/ bi-directional metering, the followings shall apply:
  - (i) If the solar net-metering facility has been in service for more than 12 months:

The active energy import, active energy export and active energy net import readings of the corresponding period of the previous year will be taken for billing purpose by the DISCOMs.

(ii) If the solar net-metering facility has been in service for less than 12 months:

The net active energy to be billed by DISCSOM per month = (Average energy consumption (imported active energy) during the last three billing cycles prior to the installation of the bi-directional/ net meter) - KWP of Solar PV generator x 124.

#### 13. LT Connectivity:

- (a) The Technical Standards for connectivity shall be as specified in the CEA's (Technical Standards for connectivity of the Distributed Generating Resources) Regulations, 2013 and as amended from time to time.
- (b) The maximum capacity for interconnection with the distribution licensee's system at a specific voltage level shall be limited to the contract demand of the consumer as per his agreement with the distribution licensee for a single net / bi-directional metering point.
- (c) The important clauses related to the technical and interconnection requirements are provided below:

| Parameter              | Reference                         | Requirement                  |  |  |
|------------------------|-----------------------------------|------------------------------|--|--|
| Overall conditions of  | OERC Distribution (Conditions of  | Reference to regulations     |  |  |
| service                | Supply) Code, 2004 and            |                              |  |  |
|                        | amendments thereto                |                              |  |  |
| Overall Grid Standards | CEA (Grid Standard) Regulations,  | Reference to regulations     |  |  |
|                        | 2010                              |                              |  |  |
| Equipment              | BIS / IEC / IEEE                  | Reference to standards       |  |  |
| Meters                 | CEA (Installation & operation of  | Reference to regulations and |  |  |
|                        | meters) Regulation 2006 and       | additional conditions issued |  |  |
|                        | amendment thereto                 | by OERC                      |  |  |
| Safety and supply      | CEA ( Measures relating to Safety | Reference to regulations     |  |  |

| Parameter        | Reference  | Requirement  |
|------------------|--|--|
|                  | and Electricity Supply)  |  |
| Harmonic Current | Regulations, 2010  IEEE 519 CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations, 2013 | Harmonic current injections from a generating station shall not exceed the limits specified in IEEE 519  |
| Synchronization  | IEEE 519 CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations, 2013                    | Photovoltaic system must be equipped with a grid frequency synchronization device. Every time the generating station is synchronized to the electricity system it shall not cause voltage fluctuation greater than +/- 5% at point of connection.  |
| Voltage          | IEEE 519 CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations, 2013                    | The voltage-operating window should minimize nuisance tripping and should be under operating range of 80% to 110% of the nominal connected voltage. Beyond a clearing time of 2 second, the photovoltaic system must isolate itself from the grid. |
| Flicker          | IEEE 519 CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations, 2013                    | Operation of Photovoltaic system should not cause voltage flicker in excess of the limits stated in IEC 61000 standards or other equivalent Indian standards, if any.  |
| Frequency        | IEEE 519 CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations, 2013                    | When the Distribution system frequency deviates outside the specified conditions (50.5 Hz on upper side and 47.5 Hz on lower side), There should be over and under frequency trip functions with a clearing time of 0.2 seconds.                   |
| DC injection     | IEEE 519 CEA (Technical Standards for Connectivity of the Distributed Generation Resources) Regulations, 2013                    | Photovoltaic system should not inject DC power more than 0.5% of full rated output at the interconnection point or 1% of rated inverter output current into distribution system under any operating conditions.                                    |
| Power Factor     | IEEE 519 CEA (Technical Standards for Connectivity of the Distributed  | While the output of the inverter is greater than 50%, a lagging power factor of  |

| Parameter             | Reference                       | Requirement                     |  |  |
|-----------------------|---------------------------------|---------------------------------|--|--|
|                       | Generation Resources)           | greater than 0.9 should         |  |  |
|                       | Regulations, 2013               | operate.                        |  |  |
| Islanding and         | IEEE 519                        | The photovoltaic system in the  |  |  |
| Disconnection         | CEA (Technical Standards for    | event of fault, voltage or      |  |  |
|                       | Connectivity of the Distributed | frequency variations must       |  |  |
|                       | Generation Resources)           | island/disconnect itself within |  |  |
|                       | Regulations, 2013               | IEC standard on stipulated      |  |  |
|                       |                                 | period.                         |  |  |
| Overload and Overheat | IEEE 519                        | The inverter should have the    |  |  |
|                       | CEA (Technical Standards for    | facility to automatically       |  |  |
|                       | Connectivity of the Distributed | switch off in case of overload  |  |  |
|                       | Generation Resources)           | or overheating and should       |  |  |
|                       | Regulations, 2013               | restart when normal             |  |  |
|                       |                                 | conditions are restored.        |  |  |
| Paralleling Device    | IEEE 519                        | Paralleling device of           |  |  |
|                       | CEA (Technical Standards for    | photovoltaic system shall be    |  |  |
|                       | Connectivity of the Distributed | capable of withstanding 220%    |  |  |
|                       | Generation Resources)           | of the normal voltage at the    |  |  |
|                       | Regulations, 2013               | interconnection point.          |  |  |

The technical and interconnection requirement shall undergo change as and when the above Regulation / Standards get amended.

#### 14. Operation and Maintenance

- (a) The solar PV projects shall comply with the relevant standards and guidelines specified by the MNRE / BIS and CEA. The responsibility of operation and maintenance of the solar PV projects including all its accessories and apparatuses lies with the consumer. The design and installation of the solar PV project should be equipped with appropriately rated protective devices to sense any abnormality in the system and carry out automatic isolation of the solar PV project from the network of the Distribution Licensee. The inverters used should meet the necessary quality requirements as specified and checked by the Supply Engineer before putting into service. The protection logics should be tested before commissioning of the plant. The installation shall meet all safety standards and safety certificates for the installations should be obtained from the appropriate authorities.
- (b) The automatic isolation or islanding protection of solar PV projects should be ensured for, no grid supply, low or over voltage conditions and within the required response time. Fuses and fast acting circuit breakers of adequate rating on input and output side of the inverters and disconnect / isolating switches to isolate DC and AC system for maintenance shall be provided. The consumer

- should provide for all internal safety and protective mechanism for earthing, surge, DC ground fault, transients etc. as per the CEA regulation/standards.
- (c) To prevent back feeding and possible accidents when there is no supply from distribution licensee's side, Double pole /Triple pole isolating disconnect switches which can be locked by distribution licensee personnel should be provided by the consumer. This is in addition to automatic sensing and isolating on grid supply failure etc and also in addition to internal disconnect switches. In the event of distribution licensee's supply failure, the consumer has to ensure that there will not be any solar power being fed to the system of distribution licensee. The consumer is solely responsible for any accident to human beings /animals whatsoever (fatal /non-fatal / departmental /non-departmental) that may occur due to back feeding from the solar PV projects when there is supply failure from distribution licensee's side. Distribution licensee reserves the right to disconnect the installation at any time in the event of damage to its grid, meter, etc. or to prevent further accident or damage.
- (d) The consumer shall abide by all the codes and regulations issued by the CEA/OERC to the extent applicable and in force from time to time. The consumer shall comply with CEA/IEGC/OGC/OERC/distribution licensee's requirements with respect to safe, secure and reliable function of the Solar PV projects. The power injected into the distribution licensee's system shall be of the required quality in respect of wave shape, frequency, harmonic standard and absence of DC components etc.
- (e) The Solar PV projects shall restrict the harmonic generation within the limit specified in the agreement or specified by the Central Electricity Authority by regulation.
- (f) The Solar PV projects established under net metering/ bi-directional metering procedure may have also battery backup.
  - When the consumer prefers LT connectivity with battery backup (full load backup/partial load backup), the inverter shall have separate backup wiring to prevent the battery/DG power from flowing into the grid in the absence of grid supply and manual isolation switch shall also be provided. The manual isolation switch shall have locking facilities to enable distribution licensee personnel to keep it switched off and locked during maintenance works.

(g) The inverter standard shall be such that it should not allow solar power/battery power/DG power to extend to distribution licensee's supply system on failure of distribution licensee's grid supply, irrespective of the LT connectivity options.

(h) The inverter should be a sine wave inverter. Harmonic standards shall be as per IEEE 519. To avoid DC injection into the grid and to ensure other power quality parameters, the AC output of the inverter shall be connected through an Isolation Transformer to the distribution licensee's system.

(i) Application for Solar PV Project connectivity shall be submitted to the concerned section officer along with application fee specified in this order.

(j) The net-metering / bi-directional metering connection agreement is furnished in Annexure-III.

#### **15.** Applicability of Renewable Energy Certificates and RPO

Solar Energy generated by Net-metering/ bi-directional metering project is not eligible for Renewable Energy Certificate (REC). The energy generated by an eligible consumer, who is not defined as an obligated entity from the solar PV projects under net-metering arrangement shall qualify as deemed Renewable Purchase Obligation (RPO) for the distribution licensee/ bulk supply licensee. The Distribution Licensee shall furnish a copy of solar energy generated by the eligible consumer to GRIDCO every year in the month of April for the solar energy generation of the previous financial year.


16. The present order supersedes the earlier order of the Commission on Net Metering / Bi-directional Metering and their connectivity with respect to Rooftop Solar PV Projects on the rooftop of Government/ PSU owned buildings dated 26.11.2014 and its amendments dated 18.05.2015 and 16.09.2015. This order is applicable both to the prospective net metered solar consumers and to the existing similar categories of consumers.

By Order of the Commission

**Sd** /-SECRETARY I/c

#### Annexure- 1

### Overview of a basic grid interactive Photo Voltaic system



SPD- Surge Protective Device, PCU- Power Conditioning Unit, SM-Solar Generation Meter, CM- Consumer Meter (Net meter or Bi-directional meter)

<sup>\*</sup> The actual connectivity diagram may vary depending upon site specification.

## FORM-1

## **Net Metering/Bi-directional Metering Connection Application**

|          | _   |
|----------|-----|
| <i>'</i> | ^`ا |
|          |     |
|          |     |

The Section Officer/Designated Officer Distribution Licensee [Name of office]

Date:

 $\,$  I  $\,$  / we herewith apply for a solar energy net-metering/ bi-directional metering connection at the service connection for the Solar PV Project of which details are given below

| 1.  | Name of applicant  |  |
|-----|--|--|
| 2.  | Address of applicant   |  |
| 3.  | Service connection number  |  |
| 4.  | Telephone number(s)  |  |
| 5.  | Email ID   |  |
| 6.  | Solar PV Project capacity (Watts)                                      |  |
| 7.  | Solar PV Project inverter make and type                                |  |
| 8.  | Solar PV Project inverter has automatic isolation protection $(Y/N)$ ? |  |
| 9.  | Has a Solar Generation Meter been installed $(Y/N)$ ?                  |  |
| 10. | Expected date of commissioning of solar PV Project.                    |  |
| 11. | Concerned safety requirement fulfilled (Y/N)                           |  |
|     |  |  |

#### **DECLARATION**

I do hereby declare that the information furnished above is true to my knowledge and belief.

Signature with Name: Address:

#### **FORM - 2**

# Standard Agreement Form for Net-metering/ Bi-directional metering of Solar PV Project

| This Agreement is made and entered into at (location) on this (date) day of (month)  |
|--|
| between The Eligible Consumer, residing at (address) as first party AND  |
| Distribution Licensee (herein after called as Distribution Licensee) and having its registered   |
| office at (address) as second party of the agreement.  |
| And whereas, the Distribution Licensee agrees to benefit the eligible consumer for the electricity generated from his Solar PV Project of capacity watts and as per conditions of this agreement and net-metering/ bi-directional metering orders issued by the Odisha |
| Electricity Regulatory Commission.   |
|  |

Both the party hereby agrees to as follows:

#### 1. Eligibility

1.1 Eligibility for net-metering/ bi-directional metering has been as specified in the relevant order of the Odisha Electricity Regulatory Commission. Eligible consumer is required to be aware and understood, in advance, of the standards and conditions of his system for being integrated into distribution system in conformity with the order of the Commission and other conditions mentioned.

#### 2. Technical and Interconnection Requirements

- 2.1 The eligible consumer agrees that his solar PV Project and net' metering/ bi-directional metering system will conform to the standards and requirements specified in the following Regulations and codes as amended from time to time.
  - a) CEA's (Technical Standards for connectivity of the Distributed Generating Resources) Regulations, 2013 and amendments thereto.
  - b) Central Electricity Authority (Installation and Operation of Meters) Regulation 2006 and amendments thereto.
  - c) OERC Distribution (Conditions of Supply) Code, 2004 and amendments thereto.
- 2.2 Eligible consumer agrees that he has installed / will install, prior to connection of Photovoltaic system to Distribution Licensee's distribution system, an isolation device

(both automatic and inbuilt within inverter and external manual relays) and agrees for the Distribution Licensee to have access to and operation of this, if required and for repair and maintenance of the distribution system.

- 2.3 Eligible consumer agrees that in case of a power outage from Distribution Licensee's system the photo voltaic plant will not inject any power into Licensee's distribution system and also ensures that automatic isolation or islanding protection of Solar PV system.
- 2.4 All the equipment connected to distribution system must be compliant with relevant international (IEEE/IEC) or Indian standards (BIS) and installations of electrical equipment must comply with Central Electricity Authority (Measures of Safety and Electricity Supply) Regulations, 2010 and amendments thereto.
- 2.5 Eligible consumer agrees that licensee will specify the interface/inter-connection point and metering point.
- 2.6 Eligible consumer and licensee agree to comply with the relevant CEA regulations in respect of operation and maintenance of the plant, drawing and diagrams, site responsibility schedule, harmonics, synchronization, voltage frequency, flicker etc.,
- 2.7 Due to Distribution Licensee's obligation to maintain a safe and reliable distribution system, eligible consumer agrees that if it is determined by the Distribution Licensee that eligible consumer's photovoltaic system either causes damage to and/or produces adverse effects on other consumers or Distribution Licensee's assets, eligible consumer will have to disconnect photovoltaic system immediately from the distribution system upon direction from the Distribution Licensee and correct the problem at his own expense prior to a reconnection.

#### 3. Clearances and Approvals

3.1 The eligible consumer agrees to obtain all the necessary approvals and clearances (environmental and grid connected related) before connecting the photovoltaic system to the distribution system.

#### 4. Access and Disconnection

4.1 Distribution Licensee shall have access to metering equipment and disconnecting means of photovoltaic system, both automatic and manual, at all times.

4.2 In emergency or outage situation, where there is no access to a disconnecting means, both automatic and manual, such as a switch or breaker, Distribution Licensee may disconnect service to the premise.

#### 5. Liabilities

- 5.1 Eligible consumer and Distribution Licensee will indemnify each other for damages or adverse effects from either party's negligence or intentional misconduct in the connection and operation of photovoltaic system or Distribution Licensee's distribution system.
- 5.2 Distribution Licensee and eligible consumer will not be liable to each other for any loss of profits or revenues, business interruption losses, loss of contract or loss of goodwill or for indirect, consequential, incidental or special damages, including, but not limited to, punitive or exemplary damages, whether any of the said liability, loss or damages arise in contract, or otherwise.
- 5.3 Distribution Licensee shall not be liable for delivery or realization by eligible consumer for any fiscal or other incentive provided by the Central/State government beyond the scope specified by the Commission in its relevant Order.

#### 6. Commercial Settlement

6.1 All the commercial settlement under this agreement shall follow the Net metering order issued by the OERC.

#### 7. Connection Costs

7.1 The eligible consumer shall bear all costs related to setting up of photovoltaic system including metering and interconnection costs. The eligible consumer agrees to pay the actual cost of modifications and upgrades to the service line required to connect photovoltaic system in case it is required.

#### 8. **Termination**

- 8.1 The eligible consumer can terminate agreement at any time by providing Distribution Licensee with 90 days prior notice.
- 8.2 Distribution Licensee has the right to terminate Agreement on 30 days prior written notice, if eligible consumer breaches a term of this Agreement and does not remedy the breach within 30 days of receiving written notice from Distribution Licensee of the breach.

| 8.3                          | Eligible consumer agrees that upon termination of this Agreement, he must disconnect |             |                      |   |  |  |
|------------------------------|--|-------------|----------------------|---|--|--|
|                              | the photovoltaic system from Distribution Licensee's distribution system in a timely |             |                      |   |  |  |
|                              | manner and to Distribution Licensee's satisfaction.                                  |             |                      |   |  |  |
| In the                       | In the witness, whereof of Mr for and on behalf of                                   |             |                      |   |  |  |
| (Eligible consumer) and Mr f |  |             | for and on behalf of |   |  |  |
| (Distri                      | bution Licensee) sign this agreement in two or                                       | riginals.   |                      |   |  |  |
|                              |  |             |                      |   |  |  |
| Eligibl                      | le Consumer Name   |             | Dis                  | stribution Licensee Name                        |  |  |
| Address                      |  | Designation |                      |   |  |  |
| Servic                       | rvice Connection Number Office Address   |             | fice Address         |   |  |  |
|                              | ss to the execution half of eligible consumers                                       |             |                      | s to the execution alf of Distribution Licensee |  |  |
| 1.                           | Name :<br>Address :  | 1           | 1.                   | Name :<br>Address :                             |  |  |
| 2.                           | Name:<br>Address:  | 2           | 2.                   | Name:<br>Address:                               |  |  |

<sup>\*</sup> The Licensee may impose any other condition(s) depending upon the requirement of connectivity of a specific project. The additional condition(s), if any, should conform OERC Distribution (Condition of Supply) Code, 2004.